

EC type examination certificate**EG-Baumusterprüfbescheinigung****CE-0085CS0173**Product Identification No.
Produkt-Identnummer**Field of Application**
*Anwendungsbereich*EC Gas Appliances Directive (2009/142/EC)
EG-Gasgeräterichtlinie (2009/142/EG)**Owner of Certificate**
*Zertifikatinhaber*Ferroli S.p.A.
Via Ritonda 78A, I-37047 San Bonifacio (VR)**Distributor**
*Vertreiber*Ferroli S.p.A.
Via Ritonda 78A, I-37047 San Bonifacio (VR)**Product Category**
Produktart

Boilers: Boiler without burner (3117)

Product Description
Produktbezeichnung

boiler for forced draught burners

Model
Modell

TP3 COND...

Countries of Destination
Bestimmungsländer

European Union, CH, IS, NO, TR

Test Reports
*Prüfberichte*type testing: K 2055 2017 B3 rev.01 from 19.02.2018 (TRG)
type testing: K 2055 2017 T1 from 19.02.2018 (TRG)
type testing: K 2055 2017 T2 from 19.02.2018 (TRG)**Test Basis**
*Prüfgrundlagen*2009/142/EG (30.11.2009)
DIN EN 303-1 (01.11.2017)
DIN EN 303-3 (01.10.2004)
DIN EN 303-3/Ber (01.07.2007)**File Number**
Aktenzeichen

17-0478-GEE

11.04.2018 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EC Directive

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EG-Richtlinie 2009/142/EG.

DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Elektrical Data
Elektrische Daten 230 V AC, 50 Hz

Installation Codes <i>Installationsarten</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
B23	CH, EU, IS, NO, TR	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
TP3 COND 65	nominal heat output: 18,0...59,5 kW heat input (Hi): 18,4...61,3 kW	
TP3 COND 100	nominal heat output: 27,7...91,5 kW heat input (Hi): 28,3...94,3 kW	
TP3 COND 150	nominal heat output: 41,6...137,3 kW heat input (Hi): 42,5...141,5 kW	
TP3 COND 230	nominal heat output: 63,8...210,5 kW heat input (Hi): 65,1...217,0 kW	
TP3 COND 370	nominal heat output: 102,6...338,6 kW heat input (Hi): 104,7...349,1 kW	
TP3 COND 500	nominal heat output: 138,7...457,5 kW heat input (Hi): 141,5...471,7 kW	
TP3 COND 650	nominal heat output: 180,3...594,8 kW heat input (Hi): 184,0...613,2 kW	

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

The appliance categories and the gas supply pressures are according to the gas burner in use.