

EU type examination certificate

EU-Baumusterprüfbescheinigung

CE-0035CP0102


Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Ferrol S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
Distributor <i>Vertreiber</i>	Ferrol S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
Product Category <i>Produktart</i>	Boilers: Boiler without burner (3117)
Product Description <i>Produktbezeichnung</i>	Boiler for forced draught gas burners
Model <i>Modell</i>	PREXTHERM RSW...
Countries of Destination <i>Bestimmungsländer</i>	AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR
Test Reports <i>Prüfberichte</i>	type testing: K 1214 2018 B17 from 04.05.2018 (TRG) supplement test: K 1214 2018 T16 from 04.05.2018 (TRG) type testing: K 1214 2018 B17 rev.01 from 20.03.2019 (TRG) supplement test: K 1214 2018 T16 rev.01 from 20.03.2019 (TRG)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 303-1 (01.11.2017)
Date of Expiry / File No. <i>Ablaufdatum / AZ</i>	25.06.2028 / 21-0575-GEA

7028-04-A-DE

06.12.2021 Pz A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle





Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Installation Codes <i>Installationsarten</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
B23	AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
PREXTHERM RSW 401N;	nominal heat output: 260,0...401,0 kW	
PREXTHERM RSW 399N	heat input (Hi): 277,5...434,0 kW	
PREXTHERM RSW 525N	nominal heat output: 341,0...525,0 kW	
	heat input (Hi): 364,5...567,0 kW	
PREXTHERM RSW 600N	nominal heat output: 390,0...600,0 kW	
	heat input (Hi): 417...648,0 kW	
PREXTHERM RSW 720N	nominal heat output: 468,0...720,0 kW	
	heat input (Hi): 502,0...777,0 kW	
PREXTHERM RSW 820N	nominal heat output: 533,0...820,0 kW	
	heat input (Hi): 566...881,0 kW	
PREXTHERM RSW 940N	nominal heat output: 611,0...940,0 kW	
	heat input (Hi): 651,0...1011,0 kW	
PREXTHERM RSW 1060N	nominal heat output: 660,0...1000,0 kW	
	heat input (Hi): 717,0...1075,0 kW	

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

The appliance categories and the gas supply pressures are according to the gas burner in use.

