

**EU type examination certificate****EU-Baumusterprüfbescheinigung****CE-0085CS0173**Product Identification No.  
Produkt-Identnummer

|                                                             |                                                                                                                                                                         |
|-------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Field of Application</b><br><i>Anwendungsbereich</i>     | EU Gas Appliances Regulation (EU/2016/426)<br><i>EU-Gasgeräteverordnung (EU/2016/426)</i>                                                                               |
| <b>Owner of Certificate</b><br><i>Zertifikatinhaber</i>     | Ferrol S.p.A.<br>Via Ritonda 78A, I-37047 San Bonifacio (VR)                                                                                                            |
| <b>Distributor</b><br><i>Vertreiber</i>                     | Ferrol S.p.A.<br>Via Ritonda 78A, I-37047 San Bonifacio (VR)                                                                                                            |
| <b>Product Category</b><br><i>Produktart</i>                | Boilers: Boiler without burner (3117)                                                                                                                                   |
| <b>Product Description</b><br><i>Produktbezeichnung</i>     | boiler for forced draught burners                                                                                                                                       |
| <b>Model</b><br><i>Modell</i>                               | TP3 COND...                                                                                                                                                             |
| <b>Countries of Destination</b><br><i>Bestimmungsländer</i> | European Union, CH, IS, NO, TR                                                                                                                                          |
| <b>Test Reports</b><br><i>Prüfberichte</i>                  | supplement test: K 2055 2018 B9 from 26.10.2020 (TRG)<br>supplement test: K 2055 2018 Z8 from 26.10.2020 (TRG)<br>supplement test: K 2055 2018 E7 from 26.10.2020 (TRG) |
| <b>Test Basis</b><br><i>Prüfgrundlagen</i>                  | EU/2016/426 A III B (09.03.2016)<br>DIN EN 303-1 (01.11.2017)<br>DIN EN 303-3 (01.10.2004)<br>DIN EN 303-3/Ber (01.07.2007)                                             |
| <b>Date of Expiry / File No.</b><br><i>Ablaufdatum / AZ</i> | 04.07.2028 / 21-0575-GEA                                                                                                                                                |

70028-04-A-DE

06.12.2021 Pz A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der ZertifizierungsstelleDeutsche  
Akkreditierungsstelle  
D-ZE-16028-01-01DVGW CERT GmbH  
ZertifizierungsstelleJosef-Wirmer-Str. 1-3  
53123 BonnTel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993www.dvgw-cert.com  
info@dvgw-cert.com

**Elektrical Data**  
*Elektrische Daten*

230 V AC, 50 Hz

| Installation Codes<br><i>Installationsarten</i> | Countries of Destination<br><i>Bestimmungsländer</i> | Remarks<br><i>Bemerkungen</i> |
|-------------------------------------------------|------------------------------------------------------|-------------------------------|
| B23                                             | CH, EU, IS, NO, TR                                   |                               |

| Type<br><i>Typ</i> | Technical Data<br><i>Technische Daten</i>                                  | Remarks<br><i>Bemerkungen</i> |
|--------------------|----------------------------------------------------------------------------|-------------------------------|
| TP3 COND 65        | nominal heat output: 18,0...59,5 kW<br>heat input (Hi): 18,4...61,3 kW     |                               |
| TP3 COND 100       | nominal heat output: 27,7...91,5 kW<br>heat input (Hi): 28,3...94,3 kW     |                               |
| TP3 COND 150       | nominal heat output: 41,6...137,3 kW<br>heat input (Hi): 42,5...141,5 kW   |                               |
| TP3 COND 230       | nominal heat output: 63,8...210,5 kW<br>heat input (Hi): 65,1...217,0 kW   |                               |
| TP3 COND 370       | nominal heat output: 102,6...338,6 kW<br>heat input (Hi): 104,7...349,1 kW |                               |
| TP3 COND 500       | nominal heat output: 138,7...457,5 kW<br>heat input (Hi): 141,5...471,7 kW |                               |
| TP3 COND 650       | nominal heat output: 180,3...594,8 kW<br>heat input (Hi): 184,0...613,2 kW |                               |
| TP3 COND 820       | nominal heat output: 489,0...734,0 kW<br>heat input (Hi): 498,0...749,0 kW |                               |
| TP3 COND 1000      | nominal heat output: 595,0...916,0 kW<br>heat input (Hi): 608,0...935,0 kW |                               |

**Hints of Utilization /Remarks**
***Verwendungshinweise / Bemerkungen***

The appliance categories and the gas supply pressures are according to the gas burner in use.

