



Certificate number: 2311746 (2)

Issued 23/11/2023

Expires 22/11/2028

Kiwa G3 Building Regulation (KUKG3) – Unvented Water Heater & KUKreg4 Certification

Evaluation Guideline – Kiwa UK – EG003 – Building Regulation G3

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

Ferrol S.p.A.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

The Building Regulations 2010 (England & Wales). Requirements G3, L1 & Regulation 7.

The Building (Scotland) Regulations 2004. Schedule 5, Section 6 clause 4.9, 6.3 & 6.4.

The Building Regulations (Northern Ireland) 2012. Part B clause 23 & Part P clause 88.

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> to ensure that the certificate is still valid.

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:
Ferrol S.p.A
Via Ritonda 78A
37047 S.Bonifacio (VR)
Italy



Product Certificate

Appendix to Certificate number: 2311746

The following products belong to this certificate

Product description:	Range of direct (electrically heated) or indirectly heated (solar coil) hot water storage cylinders with an enamel internal coating. Supplied with a pressure reducing valve set at 3.5bar, expansion relief valve set at 6 bar, single check valve, expansion vessel and tundish. Fitted with a temperature and pressure relief valve set at 7 bar & 90°C. ATS3 – Without Production Surveillance.
Models:	2COBB04F EGEA 200 LT UK 2COBB05F EGEA 260 LT UK 2COBB06F EGEA 200 LT-S UK 2COBB07F EGEA 260 LT-S UK 2CP0B24F EGEA TECH 200 LT UK 2CP0B25F EGEA TECH 260 LT UK 2CP0B26F EGEA TECH 200 LT-S UK 2CP0B27F EGEA TECH 260 LT-S UK
Size:	1" BSP(F).
Scope:	Manufacturer recommended maximum working pressure 7 Bar & maximum operating temperature 82°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 85°C.
Marking:	Manufacturers name, address, model, and technical information on label.
Materials:	Non-metallic materials assessed (BS6920) to point of discharge.
Backflow protection notes:	Domestic unvented primary circuits may be filled or replenished by means of a temporary connection between the primary circuit and the supply pipe. An appropriate double check valve shall be installed at the point of connection to the supply pipe. A permanent connection between the primary circuit and the supply pipe may be made via a CA backflow prevention device or some other no less effective backflow prevention device.
Additional notes:	All water contact & exposed components satisfy opacity requirements. Sealed primary circuits and /or secondary hot water systems shall incorporate a means for accommodating the thermal expansion of water to prevent any discharge from the circuit and/or system except in an emergency situation. Expansion vessels should be installed in the vertical orientation, where expansion vessels are not installed in the vertical orientation appropriate measures should be used to ensure that there is adequate flow through of water through the expansion vessel and they are located so that the length of the connecting pipework is kept to a minimum.

Extra Notes: