



EU DECLARATION OF CONFORMITY

Company Name and Address:

Ferroli SpA
via Ritonda 78/A
IT-37047 San Bonifacio (VR) Italy
tel. +39 045 6139411
info@ferroli.com

The declaration of conformity is issued under the sole responsibility of Ferroli SpA.

Appliance type: CONDENSING BOILER

TRADEMARK: FERROLI

Identification of product:

OPERA 70
OPERA 125
OPERA 220
OPERA 320

The appliance types satisfy the essential requirements of the relevant directives and Standards:

92/42/EEC BED Directive
2014/35/EC LVD Directive
2009/125/EC Ecodesign Directive
2014/30/EC EMC Directive
2016/426 EU Regulation

DIN EN 15502-1 (01.10.2012)
DIN EN 15502-2-1 (01.01.2013)
EN 60335-1 :2002 + A 1 :2004 + A 11 :2004 +
A 12:2006 + A2:2006 + A 13:2008
EN 55014-1:2006 + A 1 :2009
EN 55014-2:1997+A1:2001+A2:2008
EN 61000-3-2:2006 - EN 61000-3-3:2008
EN 60335-2-102:2006 + A 1:2010

PIN nr: 0085
Certificate nr: 0085CL0441
issued by: DVGW CERT GmbH
Address: Josef-Wirmer Straße 1-3 D-53123 Bonn
Type examination report: K 1018 2019 B15 - K 1018 2019 B16
issued by: TÜV Rheinland Energy GmbH
Address: Am Grauen Stein, D-51105 Köln

Any change to the appliance and/or any use not according the instructions will lead the invalidation of this Declaration of Conformity

Signed for and on behalf of:

San Bonifacio, 02/09/2019
(Place, date)



www.ferroli.com


Country Manager
Roberto Del Corso

EC type examination certificate

EG-Baumusterprüfbescheinigung

CE-0085CL0441

Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Efficiency Directive (92/42/EEC) <i>EG-Wirkungsgradrichtlinie (92/42/EWG)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Ferrol S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
Distributor <i>Vertreiber</i>	Ferrol S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
Product Category <i>Produktart</i>	Boilers: Condensing water heater (3102)
Product Description <i>Produktbezeichnung</i>	Condensing boiler with fan-assisted burner in modulating operation method and with enclosed combustion chamber
Model <i>Modell</i>	Quadrifoglio...; Opera...
Type of Boiler <i>Heizkesseltyp</i>	condensing boiler
Test Reports <i>Prüfberichte</i>	supplement test: K 1018 2019 B16 from 14.05.2019 (TRG)
Test Basis <i>Prüfgrundlagen</i>	EU/92/42 (21.05.1992)
File Number <i>Aktenzeichen</i>	19-0613-GWR

30.09.2019 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of heating boilers under EC Directive 92/42/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Heizkesseln nach der Richtlinie 92/42/EWG.

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-04DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Energy Labelling <i>Energieeffizienzkennzeichnung</i>
Quadrifoglio B 70; Opera 70	nominal heat output: 13,7...64,4 kW nominal heat input (Hi): 14,0...65,5 kW	
Quadrifoglio B 125; Opera 125	nominal heat output: 22,5...114,0 kW nominal heat input (Hi): 23,0...116,0 kW	
Quadrifoglio B 220; Opera 220	nominal heat output: 40,2...204,0 kW nominal heat input (Hi): 41,0...207,0 kW	
Quadrifoglio B 320; Opera 320	nominal heat output: 60,8...294,5 kW nominal heat input (Hi): 62,0...299,0 kW	